

June 14, 2006

VAN HANDEL CONCRETE PRODUCTS
KEN VAN HANDEL
5325 N. BALLARD RD.
APPLETON WI 54913-8941

Re: Description: SEWAGE TANK, SITE CONSTRUCTED
Manufacturer: VAN HANDEL CONCRETE PRODUCTS
Product Name: SEPTIC, HOLDING OR PUMP TANK
Model Number(s): H30, S30, P30
(72.0" L.L., 42.2 GAL/IN., 48" MAX. DEPTH OF BURY, 1455 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
H40, S40, P40
(75.0" L.L., 53.8 GAL/IN., 48" MAX. DEPTH OF BURY, 1933 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
H50, S50, P50
(74.0" L.L., 69.8 GAL/IN., 48" MAX. DEPTH OF BURY, 2474 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
H60, S60, P60
(74.0" L.L., 82.9 GAL/IN., 48" MAX. DEPTH OF BURY, 2899 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20060234

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2011.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- Construction of this product must be designed and constructed in conformance with the specifications submitted and approved by this department and the sealant manufacturer's printed directions for use for the sealant materials.
- The manufacturer must keep a set of plans and specifications for this product bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on INSERT DATE under product file number 20010251.

VAN HANDEL CONCRETE PRODUCTS

Page 2

June 14, 2006

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010251

A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov